

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. KDL/26/JUN/0029Dated: 09/06/2026It is certified that an inspection team headed by USHA.J Senior Analyst / Q.M(Name of Officers with designation) from RDW&SD, Kolar PHED inspected theSri Sai Vidhya Shala.(Name & Address of the school) on 09/06/26 (date of inspection) and on the basis of WaterTest Report (Attached) bearing no. 0029 dated 09/06/26Of District level Water sample testing laboratory (PHED Lab)Certified that the Sri Sai Vidhya Shala (Name of school)

has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till November 2026

Usha.J
ರಾಸಾಯನಿಕ ತಜ್ಞರು

ಗ್ರಾಮೀಣ ಕುಡಿಯುವನೀರು ಮತ್ತು ನೈರ್ಮಲ್ಯ ವಿಭಾಗ

Signature with Seal: ಕೋಲಾರ್Name: USHA.JDesignation: Senior Analyst / Q.M.Name & Address of the office: RDW&SD Lab,Zilla panchayat, Kolar.

To

Sri Sai Vidhya Shala.Chikkaballapura main road, behindradion oil petrol pump, Hogari, Gollahalli, Kolar.

(Name & Address of the Institution)

A.S. Sushma

For SRI SAI EDUCATIONAL TRUST

Paul D.G.

AUTHORISED SIGNATORY

SRI SAI VIDYASHALA
CHIKKABALLAPUR MAIN ROAD
HOGARI GOLLAHALLI,
KOLAR - 563101

RURAL DRINKING WATER & SANITATION DEPARTMENT, GoK
DISTRICT WATER TESTING LABORATORY, KOLAR.
 DC Office Building, Mulabagal Road, (Laboratory Address, ZP Office Compound), Kolar-563101

TEST REPORT

Customer Address :- **Sri Sai Vidhya Shala**
 Chikkaballapura main road,
 Behind indian oil petrolpump,
 Hogari, Gollahalli, Kolar.

Report date : 09/06/2026
 Report Number : **0029**
 Reference Sample received Format
 RDWSD/KOLAR/21
 Sample receipt date: 08/06/2026
 Sample code: KDL/26/JUN/0029
 Date of Sample collection & time: 08/06/2026
 Analysis start date: 08/06/2026
 Analysis completion date: 08/06/2026
 Sample collection protocol: APHA Method
 Sample quantity: **One liter**

Sample Particulars:- **RO Water**

Sl.No	Test	Results	Acceptable Limit IS 10500 : 2012 RA:2018	Permissible Limit IS 10500 : 2012 RA:2018	Protocol
Description:					
1	pH Value @25°C	6.79	6.5 – 8.5	No relaxation	IS 3025 (Part-11) : 2022
2	Specific Conductance, $\mu\text{S}/\text{cm}$ @25°C	38	—	—	IS 3025 (Part-14) : 2019
3	Odour	Agreeable	Agreeable	Agreeable	IS 3025 (Part-5 & 6):2022
4	Colour, Hazen Units, Max.	<1	5	15	IS 3025 (Part-4) :2021
5	Turbidity, NTU, Max.	<0.1	1	5	IS 3025 (Part-10) : 2023
6	Total Dissolved Solids @ 180°C, mg/l, Max.	27	500	2000	IS 3025 (Part-16) : 2023
7	Alkalinity as CaCO_3 , mg/l, Max.	8	200	600	IS 3025 (Part-23) : 2023
8	Total Hardness as CaCO_3 , mg/l, Max.	<20	200	600	IS 3025 (Part-21) : 2019
9	Calcium as Ca, mg/l, Max.	4	75	200	IS 3025 (Part-40) : 2023
10	Magnesium as Mg, mg/l, Max.	<4	30	100	IS 3025 (Part-46) : 2023
11	Chloride as Cl, mg/l, Max.	8	250	1000	IS 3025 (Part-32) : 2019
12	Sulphate as SO_4 , mg/l, Max.	<2	200	400	IS 3025 (Part-24) : 2022
13	Fluoride as F, mg/l, Max.	<0.1	1	1.5	APHA 24 th Edition 4500 -F-'D'
14	Nitrate as NO_3 , mg/l, Max.	<0.5	45	No relaxation	APHA 24th Edition 4500 - NO_3 -B
15	Iron as Fe, mg/l, Max.	<0.1	1	No relaxation	IS 3025 (Part-53) : 2024

Remarks: All above tested parameters are within the Acceptable limits.

Reviewed & Authorized By:-
 Signature :-
 (USHA J)
 (Senior Analyst CUM TM):-

Environmental conditions during sampling:- 28 Degree Celsius

Format no: RDWSD/KOLAR/23

NOTE

1. The above results relate only to the sample tested.
2. The report shall not be reproduced except in full without the prior approval of the Quality Manager.
3. Traceability: Traceability of measurements is established using CRMs
4. Samples will be discarded after 15 days from the date of report generation.
5. Decision rule is applicable as per the procedure mentioned in RDWSD/KOLAR/38
6. Sample is submitted by the customer,

For SRI SAI EDUCATIONAL TRUST

END OF THE REPORT

Ravi R. S.

AUTHORIZED SIGNATORY

A. S. Sushma
SRI SAI VIDYASHALA
 CHIKKABALLAPUR MAIN ROAD
 HOGARI GOLLAHALLI,
 KOLAR - 563101